



We help ideas meet the real world

# Compliance Statement

No. 2013-452

## Connecting Hardware, Category 6

### Company

ELKO AS  
Eyvind Lyches vei 10  
1338 Sandvika  
Norway

### Product description

Unscreened Category 6 RJ45 Jack characterised up to 250 MHz, 100  $\Omega$

### Product identification

Telesafe QuickConnect UTP Cat.6, PN 2761  
Telesafe 180 degree UTP Cat6, PN 2763

### Generic cabling and cabling components standards - Category 6 connector requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 60603-7-4:2010 (Ed. 2.0)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-T207210-03, DANAK-19/13452

### EC Cabling product ID


5687

### CS valid until

8 November 2014

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 14 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 8 November 2013

  
Lars Lindskov Pedersen  
Test Manager

  
Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)

