

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

## Fire detection and fire alarm systems - Part 4: Power supply equipment

for fire safety use in fire detection and fire alarm systems for buildings, with specification as specified on page 2 in this certificate.

### Product name: Milleteknik Rack and Milleteknik Nova

placed on the market under the name or trademark of

#### Milleteknik AB

Ögärdesvägen 8B  
SE-433 30 Partille, Sweden

and produced in the manufacturing plant

same as above

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standards

### EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002 and EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### constancy of performance of the construction product.

This certificate was first issued on 2017-12-18 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.



Lennart Aronsson  
Product Certification Manager



Martin Tillander  
Project Manager

Certificate 0402-CPR-SC1328-17 | issue 1 | 2017-12-18

RISE Research Institutes of Sweden AB | Certification  
Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
certifiering@ri.se | www.ri.se

2017-07-06



6P07698-02



## Specification

| Type definition | Power unit | Battery size [Ah] |
|-----------------|------------|-------------------|
| RACK 27 150-1HE | HRP-300-24 | 28-200            |
| RACK 27 250-2HE | HRP-600-24 | 45-300            |
| RACK 54 70-1HE  | HRP-300-48 | 14-100            |
| RACK 54 130-2HE | HRP-600-48 | 20-200            |
| NOVA 27 250-FLX | HRP-600-24 | 45-200            |
| NOVA 27 150-FLX | HRP-300-24 | 20-200            |
| NOVA 27 100-FLX | DRP-240-24 | 20-155            |
| NOVA 27 50-FLX  | DR-120-24  | 20-65             |
| NOVA 13 100-FLX | DR-120-12  | 20-130            |
| NOVA 27 100-XS2 | DRP-240-24 | 14-120            |
| NOVA 27 50-XS2  | DR-120-24  | 7-70              |
| NOVA 27 30-XS2  | RS-75-24   | 7-42              |
| NOVA 13 100-XS2 | DR-120-12  | 14-120            |
| NOVA 13 50-XS2  | RS-75-12   | 14-84             |



Certificate 0402-CPR-SC1328-17 | issue 1 | 2017-12-18

RISE Research Institutes of Sweden AB | Certification